

# Thermal Resistance Test Report

Date:2022/01/21

Engineer: Ken



## Test Condition

Heat Flux	Pressure	Test Duration	Ambient Temp	Convection
35 /65 /80 /125 Watts	28lbf /12.7 kgf	60 minutes	45°C	Natural Convection

## Test Data

Sample	Tc (°C)	Ta(°C)	Fan Speed (RPM)	F (kgf)	Q (W)	R (°CW)
1	51.9	45.4	7831	12.79	35	0.186
2	58.6	46.0	7842	12.91	65	0.194
3	61.3	46.0	7878	12.91	80	0.191
4	70.0	46.2	7907	13.01	125	0.190

Part Number:

**RGD3226-002**

Description:

**2U CPU COOLER FOR INTEL**

**SOCKET LGA1700**

**PROCESSORS**


## Test Result

Q (W)	Tc(°C)	R (°CW)
35	51.9	0.186
65	58.6	0.194
80	61.3	0.191
125	70.0	0.190

# Thermal Resistance Test Report



## NATURAL CONVECTION



## CIRCULATING CONVECTION

- CPU Cooler Thermal Resistance Measurement Apparatus with Natural Convection Chamber ,4 sets of 650 watts Infrared Radiation Heaters.
- Operating Temperature : Room Temperature ~ 70°C
- CPU Cooler Thermal Resistance Measurement Apparatus with Programmable temperature and humidity chamber, Through a mechanical circulation system, using fans and heating coils.
- Operating Temperature : -40°C ~ 150°C

# Compression Force Test Report

Date: 2022/10/11

Engineer: Vic



Part Number:

**RGD3226-002**

Description:

**2U CPU COOLER FOR INTEL SOCKET**

**LGA1700 PROCESSORS**

## Test Criterion

Total Force of CPU Cooler		
Typical	Maximum	Minimum
32.41 lbf	35.65 lbf	29.17 lbf

## Test Condition

PCB Thickness	CPU Height (about PCB)
1.6mm	7.05mm

## Test Data

Sample	Compression Force
1	32.0 lbf
2	31.5 lbf
3	31.8 lbf
AVG	31.77 lbf

## Test Result

Pass	Compression Force of CPU Cooler = 31.77 lbf
------	---

# Compression Force Test Report

## CPU Cooler Press Load Apparatus



- The universal clip force measuring device is a tool for measuring the clip holding force for the clip on the CPU Cooler.
- Measuring pressure range 0~220lbf,; accuracy 0.1%FS